

### UNITED ENERGY CO.,LTD

Building 1, Lian Dong U Valley, Shenzhen Road, Felxi County, Hefer City, Anhui Province, China

# **United Energy Attenuation Chart**

## **Standard Monocrystalline Solar Panel**

Year	Attenuate Ratio	Attenuate Power
1	2.00%	98.00%
2	0.55%	97.45%
3	0.55%	96.90%
4	0.55%	96.35%
5	0.55%	95.80%
6	0.55%	95.25%
7	0.55%	94.70%
8	0.55%	94.15%
9	0.55%	93.60%
10	0.55%	93.05%
11	0.55%	92.50%
12	0.55%	91.95%
13	0.55%	91.40%
14	0.55%	90.85%
15	0.55%	90.30%
16	0.55%	89.75%
17	0.55%	89.20%
18	0.55%	88.65%
19	0.55%	88.10%
20	0.55%	87.55%
21	0.55%	87.00%
22	0.55%	86.45%
23	0.55%	85.90%
24	0.55%	85.35%
25	0.55% Liv	84.80%

For and on behalf of Energy (Signature(s))



# UNITED ENERGY CO.,LTD

Building 1, Lian Dong U Valley, Shenzhen Road. Fetxl County, Hefer City, Anhui Province, China

#### **Bifacial Module with Transparent Backsheet Technology**

Year	Attenuate Ratio	Attenuate Power
1	2.00%	98.00%
2	0.45%	97.55%
3	0.45%	97.10%
4	0.45%	96.65%
5	0.45%	96.20%
6	0.45%	95.75%
7	0.45%	95.30%
8	0.45%	94.85%
9	0.45%	94.40%
10	0.45%	93.95%
11	0.45%	93.50%
12	0.45%	93.05%
13	0.45%	92.60%
14	0.45%	92.15%
15	0.45%	91.70%
16	0.45%	91.25%
17	0.45%	90.80%
18	0.45%	90.35%
19	0.45%	89.90%
20	0.45%	89.45%
21	0.45%	89.00%
22	0.45%	88.55%
23	0.45%	88.10%
24	0.45%	87.65%
25	0.45%	87.20%
26	0.45%	86.75%
27	0.45%	86.30%
28	0.45%	85.85%
29	0.45%	85.40%
30	0.45%	ted 84.95%

For and on behall of Co., Limited
United Energy 源有限公司
安徽合纵新能源有限公司
Authorized Signature(s)